

Addendum No. 1

Notice to Bidders for

Voice Over IP System

Bid No. 2021-11

for

Montville Public Schools

ADDENDUM 1 - May 21, 2021

Pre-Bid Meeting Attendance Sheet

Posted on website

Questions

1. Does the vendor need to pull one permit or a permit for each location?

Vendor is required to pull any permits required by each location and are reasonable of the cost of the fees

2. Is the footage for closets B and C correct? Yes, the footage was swapped by mistake the correct footage is:

Closet B is 296 feet

Closet C is 204 feet

3. Do we need to remove the old fiber in the schools?

Yes, we would like all old fiber removed.

4. Do we need to use J-hooks to hang the fiber?

Fiber runs must be properly supported above the drop ceiling utilizing J-Hooks or other cable support devices in accordance with TIA/EIA standards (Page 5 of RFP)

5. At the High School a U1 is not big enough for the fiber termination in Closet A. Would you have room for a U3?

Yes, once the old termination unit is removed, there will be enough room for a U3.

6. Do we need to firestop pathways?

Yes, any pathways you create or removed doing the project would need to be fire stopped and inspected at completion of the project.

7. Can we reuse the current fiber panels? If no, does it matter what brand?

All fiber panels need to be brand new, brand is not relevant.

8. At the high school, the fiber run that is out to the turf field, should we have a wall mount cabinet with a lock?

Yes, please install a wall mounted cabinet above the current location of the DVR unit that was present in the walk through.

- 9. At Mohegan elementary school, the fiber run goes thru the gym. Do we need to provide a lift to install the fiber across the gym or does the district have a lift we can use?**

Yes, the district has a lift you may use. You will need to coordinate using the lift as it is not located at Mohegan Elementary School.

- 10. What is the distance from Closet A to the Turf field location?**

The distance is estimated by google maps to be 415 feet. The conduit runs from the Music room straight out to the Turf Shed. There are old cables that can be used as a pull.

- 11. Do we need to remove the single mode fiber in Closet C at the High School?**

No, the single mode fiber is for a different purpose.

END OF ADDENDUM 1

,

+